LECTRICAL SYMBOLS			NOTE: THIS IS A MASTER LEGEND AND NOT ALL SYMBOLS, ABBREVIATIONS, ETC. ARE NECESSARILY USED ON THE DRAWING		
RE ALARM	LIGHTING	WIRING DEVICES & OUTLETS	ELECTRICAL ONE-LINE & RISER		
FIRE ALARM CONTROL PANEL/UNIT FIRE ALARM ANNUNCIATOR PANEL  CHNOLOGY — AS USED ON E302.1—E401  TELEPHONE WALL OUTLET DATA WALL OUTLET DATA WALL OUTLET DEVICE TYPES AND CONFIGURATIONS  DATA WALL OUTLET ABOVE COUNTER  MULTI—SERVICE WALL OUTLET ABOVE COUNTER  MULTI—SERVICE WALL OUTLET ABOVE COUNTER  MULTI—SERVICE FLOOR BOX; TELEPHONE AND DATA  DATA FLOOR BOX TELEPHONE FLOOR BOX TELEPHONE FLOOR BOX TELECOM. BACKBOARD  CEILING—MOUNTED DATA OUTLET	FLUORESCENT LIGHT FIXTURE: (SEE LIGHT FIXTURE SCHEDULE)  a = SWITCHED BY SWITCH "a"  A = LIGHT FIXTURE TYPE "A"  FLUORESCENT LIGHT FIXTURE WITH EMERGENCY LIGHTING BATTERY PACK  AVVV LIGHTING TRACK WITH LIGHT FIXTURE TYPES AS INDICATED  OA Q LIGHT FIXTURE — CEILING / WALL MOUNTED.  A = LIGHT FIXTURE TYPE "A"  EXIT SIGN — CEILING / WALL MOUNTED, ARROWS AS INDICATED.  A = LIGHT FIXTURE TYPE "A" (SEE LIGHT FIXTURE SCHEDULE)  SECURITY  CLOSED CIRCUIT TELEVISION  DOOR MONITOR  MD MOTION DETECTOR	\$ SINGLE POLE WALL SWITCH (NO LETTER DESIGNATION)  \$ SWITCH LETTER DESIGNATIONS AS FOLLOWS:  2 = TWO POLE WALL SWITCH  3 = THREE—WAY WALL SWITCH  0S = OCCUPANCY SENSOR  M = MOTOR RATED SWITCH  WP = WEATHER PROOF  CEILING MOUNTED OCCUPANCY SENSOR WITH POWER SUPPLY AND LOAD RELAY AS REQUIRED OR SPECIFIED.  DUPLEX RECEPTACLE — NEMA 5—20R, UNO  DOUBLE DUPLEX RECEPTACLE — NEMA 5—20R, UNO  TWIST—LOCK TYPE RECEPTACLE  GFCI TYPE RECEPTACLE*  ISOLATED GROUND TYPE RECEPTACLE*  RECEPTACLE INSTALLED 6" ABOVE COUNTER OR BACKSPLASH*  RECEPTACLE INSTALLED IN CEILING*	PANELBOARD (SEE SCHEDULES)  PANELBOARD (SEE SCHEDULES)  TX# TRANSFORMER TYPE AND RATINGS AS SHOWN  ATS#  ATS#  W/RYPASS)		
WIRELESS ACCESS POINT ENCLOSURE (NETWORK DEVICE PROVIDED BY OWNER)  FIRESTOP. REFER TO SCHEDULE BELOW FOR TYPE.  CONDUIT  CONDUIT SLEEVE  UNDERGROUND CONDUIT  TMGB/TGB (PLAN VIEW)  TELECOM. ROOM LADDER RACK  TELECOM. MAIN GROUND BUS BAR (ELEVATION VIEW)  FIBER OPTIC CROSS CONNECT (RISER VIEW)  COPPER UTP CROSS CONNECT (RISER VIEW)  TWO-POST FLOOR MOUNTED RACK (PLAN VIEW)  PROTECTOR  RESTOP SCHEDULE	STANDARD MOUNTING HEIGHTS  (AFF, AFG, UNLESS NOTED OTHERWISE)  ELECTRICAL  CONTROLS (CENTERLINE)  EXIT SIGNS (WALL MOUNTED, BOTTOM)  FIRE ALARM CONTROL PANEL/UNIT (DISPLAY)  INTERCOM (AFEA ONLY)  INTERCOMS  PANELS/PANELBOARDS (TOP)  PULL STATIONS (HANDLE)  PHOTOCELLS  RECEPTACLES (CENTERLINE)  RECEPTACLES (EXTERIOR)  RECEPTACLES (EXTERIOR)  RECEPTACLES IN EQUIPMENT ROOMS  SWITCHES (CENTERLINE)  TELEPHONES (PUBLIC)  TELEPHONE (PUBLIC)  TELEPHONE TERMINAL BOARD (BOTTOM)  VISIBLE APPLIANCES (CENTERLINE)  ANNOTATION	**DUPLEX RECEPTACLE SHOWN, SIMILAR FOR OTHERS  **DUPLEX RECEPTACLE SHOWN, SIMILAR FOR OTHERS  **PUPLEX RECEPTACLE LETTER DESIGNATIONS AS FOLLOWS:  IG = ISOLATED GROUND  WP = WEATHER PROOF COVER WR = WEATHER RESISTANT  **TELEPHONE OUTLET - FLOOR OR WALL MOUNTED. INSTALL AT SAME ELEVATION AS ADJACENT RECEPTACLE, UNO.  **DATA OUTLET - FLOOR OR WALL MOUNTED. INSTALL AT  SAME ELEVATION AS ADJACENT RECEPTACLE, UNO.  MULTI-SERVICE OUTLET; TELEPHONE AND DATA - FLOOR OR  WALL MOUNTED. INSTALL AT SAME ELEVATION AS ADJACENT  RECEPTACLE, UNO.  JUNCTION BOX/OUTLET BOX  **JUNCTION BOX/OUTLET BOX  **POWER EQUIPMENT & DEVICES**  ELECTRICAL SERVICE PANELBOARD (SURFACE OR FLUSH MOUNT)  TERMINAL CABINET (SURFACE OR FLUSH MOUNT), TYPE AS NOTED  **PLYWOOD TERMINAL BOARD FOR TELEPHONE  **SYSTEM LINE SIZE AS NOTED  **PLYWOOD TERMINAL BOARD FOR TELEPHONE  **SYSTEM LINE SIZE AS NOTED	AUTOMATIC TRANSFER SWITCH. RATINGS AS SWITCH WITH BYP RATINGS AS SHOW  SOOKW GENERATOR SEPARATELY DERIVED SOURCE RATINGS AS SHOWN  GENERATOR SEPARATELY DERIVED SOURCE RATINGS AS SHOWN  WILLITY METER (AS REQUIRED BY UTILITY)  GROUND CONNECTION  GROUND ROD  HP MOTOR  CIRCUITING & WIRING  SWITCHED HOT CONDUCTORS (SHOWN TRAILING NEUTRAL NEUTRAL CONDUCTORS UNSWITCHED HOT CONDUCTORS (SHOWN LEADING NEUTRAL OF CIRCUITS, HASH MARKS INDICATE NUMBER OF CONDUCTORS. INFORMATION AT ARROWS ARE CIRCUIT NUMBERS AND PANELBOARD.		
PROVIDE QUANTITIES AS REQUIRED IN SPECIFICATIONS.  TYPE OF FIRE—RATED PATHWAY  A EZ—PATH MINI OR EQUIVALENT  B EZ—PATH OR EQUIVALENT  C EZ—PATH WITH (1) EXTENSION OR EQUIVALENT  D EZ—PATH WITH (2) EXTENSION OR EQUIVALENT  E EZ—PATH MAX OR EQUIVALENT  F EZ—PATH SERIES 33 CONDUIT ATTACHMENT OR EQUIVALENT	1 TECHNOLOGY PLAN NOTE CALLOUT  1 TECHNOLOGY PLAN CALLOUT  PLUMBING EQUIPMENT DESIGNATION. (CONTRACTOR FURNISHED AND INSTALLED). REFER TO PLUMBING FIXTURE OR EQUIPMENT SCHEDULES  CU MECHANICAL EQUIPMENT DESIGNATION (CONTRACTOR FURNISHED AND INSTALLED UNLESS NOTED OTHERWISE)  1 DETAIL REFERENCE UPPER NUMBER INDICATES DETAIL NUMBER LOWER NUMBER INDICATES SHEET NUMBER  1 SECTION CUT DESIGNATION	SYSTEM, UNO. SIZE AS NOTED.  ELECTRICAL DISTRIBUTION PANELBOARD  TRANSFORMER  MOTOR  200/3/150  DISCONNECT SWITCH — "200/3/150" DENOTES AMPERES/POLE/FUSE NF= NON-FUSED CB= CIRCUIT BREAKER (200/3/CB)  TS TIME SWITCH  PC PHOTOCELL  HO PUSH BUTTON  SIGNALING	EQUIPMENT GROUNDING CONDUCTOR IN CONDUIT (GREEN INSULATION OR BARE)  ISOLATED GROUNDING CONDUCTOR IN CONDUIT (GREEN INSULATION WITH YELLOW TRACER)  CONDUIT CONCEALED  CONDUIT IN/UNDER FLOOR/GROUND CONSTRUCTION  EXPOSED CONDUIT  FLEXIBLE CONDUIT  LOW VOLTAGE CABLE (NOT ROUTED IN CONDUIT)  CONDUIT TURNING DOWN  CONDUIT TURNING UP		
		BO SIGNALING BELL B SIGNALING BUZZER T LV TRANSFORMER	EMERGENCY CONDUIT  COMMUNICATIONS  SI SPEAKER HORN PROJECTION TYPE S SPEAKER - CEILING MOUNT HS SPEAKER - WALL MOUNT VOLUME CONTROL M MICROPHONE JACK INTERCOM		

PE	MANUFACTURER/MODEL #		HT FIXTURE SCHED		INPUT	INPUT	DESCRIPTION	LOCATION	NOTES
	AXIS — MID BEAM SERIES	NO. 2	TYPE F54T5/830/H0/ALT0	VOLT 277	WATTS 120	VA 120	NOMINAL 8' LINEAR DIRECT FIXTURE SUSPENDED BY AIRCRAFT	SALES	3
1 <b>Δ</b>	# BMD-A-8-T5HO-1-W-277-E-1-CA (field verify)  AXIS - MID BEAM SERIES	1	F54T5/830/H0/ALT0	277	62	64	CABLE. WHITE FINISH. REFER TO ARCHITECTURAL PLANS FOR EXACT MOUNTING HEIGHTS.  NOMINAL 4' LINEAR DIRECT FIXTURE SUSPENDED BY AIRCRAFT	PERIMETER SALES	3
IA	# BMD-A-4-T5HO-1-W-277-E-1-CA (field verify)		F5415/830/H0/AL10	2//	62	04	CABLE. WHITE FINISH. REFER TO ARCHITECTURAL PLANS FOR EXACT MOUNTING HEIGHTS.	PERIMETER	3
2	BARTCO # BFL254-S32-277	2	F32T8/ADV830 ALTO	277	59	61	NOMINAL 4' LINEAR FLUORESCENT STAGGARD STRIP FIXTURE WITH ADJUSTABLE STAGGER OPTION. FIXTURE	PERIMETER DISPLAYS	3
~	LITHONIA		~~~F32T8/ADV830~~~	277	~~50~	61	SHALL BE INSTALLED IN ACCORDANCE WITH ARCHITECTURAL DETAIL. NOMINAL 4* LENSED LOW—PROFILE WRAPAROUND LINEAR	ADALIEDV PANAC	~1.7
3	# LB-2-32-277-GEB10IS-LSC-HC(TBD)	2	ALTO	277	59	01	FLUORESCENT WITH WHITE FINISH. FIXTURE SHALL BE SUSPENDED WITH CHAIN HANGERS. CHAIN HANGERS SHALL	TARCHERT RANGE	1,5
							BE CUT TO LENGTH IN FIELD. CONTRACTOR SHALL INCLUDE ALL DESIRED LENGTHS IN BID. FIXTURE SHALL BE FURNISHED		
4	LITHONIA	0	F32T8/ADV830	277	50	61	WITH LENSE SAFETY CLIPS. REFER TO ARCHITECTURAL DETAILS FOR EXACT MOUNTING HEIGHT. NOMINAL 4' LINEAR FLUORESCENT WITH WIREGUARD. FIXTURE	WAREHOUSE	2,3
.4	# C-2-32-277-GEB10IS-WGCUN	2	ALTO	2//	59	01	SHALL HAVE WHITE FINISH. FIXTURE SHALL BE SUSPENDED WITH CHAIN HANGERS. CONTRACTOR SHALL INCLUDE ALL	ELEVATOR PIT	2,3
							DESIRED LENGTHS IN BID. FIXTURE SHALL BE FURNISHED SYMMETRICAL REFLECTOR AND WIREGUARD. UL LISTED FOR		
	CIMIZAD	4	E70T0 (ADV070	077	74	7.4	DAMP LOCATIONS. REFER TO ARCHITECTURAL PLANS FOR EXACT MOUNTING HEIGHTS.  NOMINAL 4' LINEAR FLUORESCENT WITH WIREGUARD. FIXTURE	NIO 700M	7
.5	SIMKAR # IE132B11-UNV-LG48	<b> </b>	F32T8/ADV830 ALTO XTREME LAMP/	277	31	34	SHALL HAVE WHITE FINISH. FIXTURE SHALL BE SUSPENDED WITH CHAIN HANGERS. CONTRACTORS SHALL INCLUDE	MIS ROOM ELECTRICAL ROOM SPRINKLER ROOM	3
			BALLAST BY OSHRAM/SYL				ALL DESIRED LENGTHS IN BID. UL LISTED FOR DAMP LOCATIONS. REFER TO ARCHITECTURAL PLANS FOR EXACT MOUNTING HEIGHTS.	JANITOR ROOM	
_6	# FGB24-654T5HO-S1-PCL125-MVOLT	6	F54T5/830/H0/ALT0	277	360	360	NOMINAL 2X4 HIGH BAY FLUORESCENT. CLEAR LAMP SHEILDING WITH WIDE DISTRIBUTION. WHITE FINISH. FIXTURE	LOADING DOCK MAIN WAREHOUSE	2,3
							SHALL BE FURNISHED WITH CHAIN HANGERS. CONTRACTOR SHALL INCLUDE ALL DESIRED LENGTHS IN BID. FIXTURE SHALL BE UL LISTED FOR DAMP LOCATION. REFER TO ARCHITECTURAL	SHOE STOCKROOM	
.7	SIMKAR	2	F32T8/ADV830	277	59	61	PLANS FOR EXACT MOUNTING HEIGHTS.  NOMINAL 8' LINEAR FLUORESCENT STRIP WITH WIREGUARD.	GUN STOCK	2,3
	# IE2132B11-2L-UNV-(2)LG48		ALTO XTREME LAMP/ BALLAST BY				FIXTURE SHALL BE FURNISHED WITH (2) 4' SECTIONS WIRED IN TANDEM. WHITE FINISH. FIXTURE SHALL BE SUSPENDED WITH CHAIN HANGERS. CONTRACTOR SHALL INCLUDE ALL DESIRED	FIRE ARMS STOCK	
			OSHRAM/SYL				LENGTHS IN BID. REFER TO ARCHITECTURAL PLANS FOR EXACT MOUNTING HEIGHTS.		
8	LITHONIA # FSB 354L	3	F54T5/841/H0/ALT0	277	182	183	NOMINAL 1'X4' LINEAR HIGH BAY FLUORESCENT FIXTURE. CHAIN HUNG. WHITE FINISH. REFER TO ARCHITECTURAL PLAN FOR EXACT	SHOE STOCK BARGAIN CAVE	3
9	BARTCO # BFL800-1S-32-277-U8LNC4-TG4	1	F32T8/ADV830 ALTO	277	31	34	MOUNTING HEIGHTS.  NOMINAL 4' LINEAR FLUORESCENT STRIP FOR UNDERCABINET LIGHTING. FIXTURE SHALL BE PROVIDED WITH INTEGRAL ELECTRONIC	FUDGE SHOP	3
			ALIU				BALLAST, WHITE POWDERCOAT FINISH. MOUNT FIXTURE TO UNDERSIDE OF CABINET MILLWORK. REFER TO ARCHITECTURAL		
	DEL DAY		Di Transferi i				SHEETS FOR EXACT MOUNTING. CONTRACTOR SHALL PROVIDE AND INSTALL TUBE GUARDS FOR ALL LAMPS.	011.50	
1	DEL RAY # X7300.442UE/CM1-6' WHITE	4	PL-T42W/830/4P/ ALTO	277	186	188	NOMINAL 16" ROUND PENDANT HIGH BAY WITH CLEAR ACRYLIC PRISMATIC DIFFUSER. FINISH TO BE DETERMINE BY ARCHITECT PRIOR TO ORDERING. ELECTRICAL CONTRACTOR SHALL	SALES	3
							PROVIDE ALL STEMS FOR MOUNTING AND SHALL CUT AND COORDINATE INSTALLATION IN FIELD. UNDERSIDE OF FIXTURE		
							AT 13'-6" AFF. FIXTURE SHALL BE WIRED FOR DUAL-CIRCUIT OPERATION. PROVIDE WITH CLEAR BOTTOM LENSE.		
2	SPECIFIED AND PROVIDE BY OWNER	_	TO BE DETERMINED	120	500	500	ANTLIER CHANDELIER PROVIDED BY OWNER. FIXTURE SHALL BE PROVIDED WITH UL LISTED MAXIMUM WATTAGE LABEL OF 500W. GENERAL CONTRACTOR SHALL VERIFY VOLTAGE PRIOR TO	GUN LIBRARY	3
3	COPPER CANYON CL830 SERIES	_	(2) 26W CFL	120	52	53	ORDERING.  DRUM SHADE PENDANT PROVIDED BY OWNER. FIXTURE SHALL BE	CATALOG AREA	3
	PROVIDE BY OWNER		SCREW IN SELF BALLASTED				PROVIDE WITH (2) 26W CF, SCREW IN LAMPS, SELF BALLASTED. GENERAL CONTRACTOR SHALL VERIFY VOLTAGE PRIOR TO		
4	LUMEC # DOS-70MH-SG3-120-GN6TX-LMS52-574A	1	70W METAL HALIDE	277	80	84	ORDERING.  PENDANT MOUNTED DRUM SHADE FIXTURE PROVIDED AND SPECIFIED BY OWNER. GENERAL CONTRACTOR SHALL VERIFY  1	EXTERIOR PORCH	3
1	# DOS-70MH-SGS-120-GN61X-LMS32-374A	3	F32T8/ADV830/ALTO	277	85	86	VOLTAGE WITH OWNER PRIOR TO ORDERING. CABELAS GREEN.  2'X4' LINEAR FLUORESCENT RECESSED PARABOLIC TROFFER.	OFFICES	1,3
	2PM3N-G/F-B-3-32-18LD-277-GEB10IS		, ,				LOW IRIDESCENT ANODIZED DIFFUSE SILVER LOUVERS, BLACK REVEAL FINISH, COLD-ROLLER STEEL HOUSING AND A WHITE	SECURITY	
2	AMERLUX # TR-70-17-E-W -NF	1	MHC70/C/U/M/3K/	277	80	84	ENAMEL FINISH.  RECESSED ADJUSTABLE METAL HALIDE FIXTURE WITH NARROW FLOOD DISTRIBUTION. WHITE FINISH. FIXTURE SHALL BE	INTERIOR MALL	3
	# IR-70-17-E-W -NF		ALTO				FURNISHED WITH HARDWARE FOR GWB CEILING MOUNTING APPLICATION.	CEILING	
3	LIGHTOLIER # C4X420LEDDL27K-CCD-W-C4X420LED2	_	LED	277	18	20	NOMINAL 4-1/2" SQUARE APERTURE, RECESSED LED DOWNLIGHT IN A GWB CEILING APPLICATION. PROVIDE WITH WHITE TRIM.	GUN LIBRARY	3
							CONTRACTOR SHALL PAINT OUT TRIM TO MATCH CEILING IN WHICH FIXTURE WILL BE INSTALLED. PROVIDE WITH 2700K LED		
4	LITHONIA #LP8FN-32TRT-802A-MVOLT-TRW	1	PL-T32W/830/4P/ ALTO	277	36	38	MODULE.  NOMINAL 8" DIAMETER RECESSED COMPACT FLUORESCENT  DOWNLIGHT WITH CLEAR SPECULAR OPEN REFLECTOR. REFER	ENTRANCE SOFFIT	1,2,3
16	LITHONIA	2	F31T8U/ADV830/ALTO	277	62	68	TO ARCHITECTURAL DRAWINGS FOR EXACT MOUNTING.  NOMINAL 2'x2' RECESSED LENSED FLUORESCENT TROFFER125	EMPLOYEE	1,2,3
	# 2SP-G/F-2-U316-A12125-277-GEB10IS						THICK #12 PATTERN LENSE. SMOOTH HEMMED FIXTURE SIDES, COLD ROLLED STEEL HOUSING. FIVE STAGE IRON—PHOSPHATE PRE— TREATMENT WITH BAKED WHITE ENAMEL FINISH. TRIM TYPE AS	RESTROOMS	
27	LITHONIA	3	F32T8/ADV830/ALTO	277	85	86	REQUIRED.  NOMINAL 2'x4' RECESSED LENSED FLUORESCENT TROFFER125	EMPLOYEE	1,2,3
	# 2SP-F/G-3-32-A12125-277-GEB10IS		,				THICK #12 PATTERN LENSE. SMOOTH HEMMED FIXTURE SIDES, COLD ROLLED STEEL HOUSING. FIVE STAGE IRON-PHOSPHATE PRE-	LOUNGE	
88	LITHONIA	1	PL-T32W/830/4P/	120/277	' 36	38	TREATMENT WITH BAKED WHITE ENAMEL FINISH. TRIM TYPE AS REQUIRED.  NOMINAL 6" DIAMETER RECESSED COMPACT FLUORESCENT	PUBLIC	2,3
·O	# LP6FN-32TRT-6LR4-MVOLT	<b>'</b>	ALTO	120/2//		30	DOWNLIGHT WITH CLEAR SPECULAR OPEN REFLECTOR. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT MOUNTING.	RESTROOM	2,0
:9	LITHONIA # 2AV G 2 32 MDR MVOLT GEB10IS	2	F32T8/ADV830/ALTO	277	59	61	NOMINAL 2'x4' RECESSED LENSED FLUORESCENT TROFFER. INDIRECT DISTRIBUTION. SMOOTH HEMMED FIXTURE SIDES, COLD	POWER SALES	2,3
51	AMERLUX	1	T6 G12 MH 39W	277	46	50	ROLLED STEEL HOUSING. FIVE STAGE IRON-PHOSPHATE PRE- TREATMENT WITH BAKED WHITE ENAMEL FINISH.  CANOPY MOUNT-RECESSED J-BOX IN BEAM.	SALES	3
<u></u>	#MTB~39~T6~E~WT~C~277~FL~HEX	1	100W MH		110	112	CROSS BAFFLE ACESSORY.  EXTERIOR CANOPY MOUNTED LIGHT FIXTURE. FINISH AND AIMING	AREA EXTERIOR MAIN	_
<b>~~</b>	#_TFM_100M_RB_277_LPI	~1~	35W-CMH-W/				SHALL BE COORDINATED WITH OWNER.  MALL CANOPY MOUNTED LIGHT FIXTURE. COORDINATE EXACT.	VESTIBULE	
(5^	# I-CYLSR-1-35-HITPGJ5-E-BT-277-NF-BL-HEX		PG15 BASE	277 ^	<u></u>	<u></u>	LOCATION WITH ARCHITECT PRIOR TO INSTALL. CONTRACTOR SHALL ENSURE AIMING HAS BEEN APPROVED BY OWNER.  40-AMP, 2-POLE BUSWAY (5' LENGTHS): WHITE FINISH.	SALFS	<b>7</b>
	# B40-5-2-WT AMERLUX	_	_	277	_	_	40 AMP, 2-POLE BUSWAY (30 LENGTHS). WHITE FINISH.	SALES	3
1	# B40-10-2-WT AMERLUX	1	MHC70/C/U/M/3K/	277	80	84	NARROW FLOOD TRACK HEAD USED WITH BUSWAY SYSTEM.	SALES	3
2	# TB-70-17-E-WT-B-277-NF-HEX  AMERLUX	1	ALTO MHC70/C/U/M/3K/	277	80	84	WHITE FINISH. PROVIDE WITH HEXCELL LOUVER. REFER TO ARCHITECTURAL PLANS FOR EXACT MOUNTING HEIGHTS. TRACK HEAD USED WITH BUSWAY SYSTEM. WHITE FINISH.	ARCHERY	3
	# MURII-70-17-E-WT-B-277-WW AMERLUX	1	ALTO MHC70/C/U/M/3K/	277	80	84	WIDE FLOOD TRACK HEAD USED WITH BUSWAY SYSTEM.	SALES	3
<b>~~</b>	# TB-70-17-E-WT-B-277-WF-HEX	<b>~~</b>	ALTO	<b>~~~~</b>	~~~	<b>~~~</b>	WHITE FINISH. PROVIDE WITH HEXCELL LOUVER. REFER TO ARCHITECTURAL PLANS FOR EXACT MOUNTING HEICHTS	***************************************	<b>~~~</b>
⊦1	NEXXUS LIGHTING ECLIPSE II-277-4C-SBDMX-D-SV42/ 5.0605-5.0607-5.0608-5.0609/ P-CLIPS	1	250 WATT METAL HALIDE BY MANUFACTURER	277	291	305	NOMINAL 14" WIDE X 12" LONG X 7" HIGH SURFACE MOUNTED METAL HALIDE FIBEROPTIC ILLUMINATOR WITH INTERNAL COLOR WHEEL WITH THE FOLLOWING COLORS IN ORDER: DARK BLUE,	FIBEROPTIC WALL	5
	AND PHAROS ARCHITECTURAL CONTROLS		4,200K				MEDIUM BLUE, CYAN, TURQUOISE AND DMX 5-PIN CONNECTOR. SYSTEM ALSO EQUIPPED WITH 42 FIBER BUNDLE IN LENGTHS		
	LPC1/ SOFTWARE						REQUIRED AND P-CLIPS FOR 0.375" DIAMETER FIBER.		
<del>/~~</del>	# WST-2/42TRT-MD-MVOLT-DDBT	~~	<b>~~PC~T42W/630/4P/~~</b> ALTO	277	<del></del>	<del>~94~</del>	SURFACE MOUNTED EXTERIOR LIGHT PIXTURE. PROVIDE FIXTURE  WITH POWDER COAT FINISH TO MATCH PMS 357C (CABELA'S	EGRESS DOORS	<del></del>
12	WINONA	1	LED PAR 38 14 WATT	120	14	14	GREEN). CONFIRM FINISH WITH ARCHITECT PRIOR TO ORDERING. SURFACE MOUNTED EXTERIOR UP/DOWN DECORATIVE LIGHTING.	UNDER PORCH	3
	# CO-0-120V-L0/L0-CPF-F0/F0-SH0/SH0-C2-ST	ſĎ	BY CONTECH (EDISON E26 BASE, PART NO.				FINISH TO BE POOWDERCOATED TO MATCH CABELA'S GREEN PMS COLOR 357C.	COLUMNS	
3	LUMEC #DOS-70MH-SG3-120-GN6TX-CABELAS GREEN	1	1238 LEDM MHC70/C/U/M/3K/ ALTO	120	80	84	EXTERIOR DECORATIVE LIGHT FIXTURE HUNG FROM WALL BRACKET. INSTALL WITH SUSPENDED LUMINAIRE INSTALLATION	EXTERIOR WALLS	3
							(MAS) HANGING SYSTEM BY LUMEC. SUSPENSION BRACKET TO BE POWDER COATED TO MATCH FIXTURE (CABELA'S GREEN PMS 357C).		
/4	SPECIFIED AND PROVIDE BY OWNER	_	TO BE DETERMINED	120	100	100	CUSTOM WALL LANTERN PROVIDED BY OWNER. FIXTURE SHALL BE UL LISTED TO NOT EXCEED A TOTAL OF 100W. FIXTURE SHALL BE	CATALOG AREA CASH WRAP	3
							PROVIDED WITH UL LISTED LABEL. REFER TO ARCHITECTURAL DETAILS FOR MOUNTING REQUIREMENTS. GENERAL CONTRACTOR SHALL CONFIRM VOLTAGE WITH CABELA'S PRIOR TO ORDERING.	SALES COLUMNS	
/5	NEIDHARDT LIGHTING LINK S	1	18W, 2G11 LONG COMPACT	277	19	20	DECORATIVE WALL SCONCE. FINISH AND MOUNTING HEIGHT SHALL BE COORDINATE WITH ARCHITECT.	CUSTOMER RESTROOMS	3
			FLUORESCENT LAMP						
(1	SURELITES # EUS70R-SD	_	INCLUDED	MVOLT	5	5	LED EDGE LIT EXIT SIGN WITH UNIVERSAL MOUNT, EMERGENCY BATTERY BACK-UP, AND SELF-TEST DIAGNOSTICS. SINGLE OR DOUBLE FACE AS REQUIRED. REFER TO ARCHITECTURAL PLANS	CUSTOMER EXITS	3
(2	SURELITES	_	INCLUDED	MVOLT	5	5	FOR NUMBER OF FACES AND ARROWS REQUIRED. RED LETTERS  THERMOPLASTIC LED EXIT SIGN, OFF—WHITE FINISH. SINGLE OR	BOH EXITS	3
· <b>-</b>	# LPX70RWH-SD		- 				DOUBLE FACE AS REQUIRED. REFER TO ARCHITECTURAL PLANS FOR NUMBER OF FACES AND ARROWS REQUIRED. RED LETTERS		

3. CABELAS SHALL PURCHASE AND DELIVER LIGHT FIXTURES AND LAMPS AND ELECTRICAL CONTRACTOR SHALL INSTALL LIGHT FIXTURES AND LAMPS.

4. CONTRACTOR SHALL PROVIDE TUBE GUARDS.

5. OWNER PROVIDED EQUIPMENT AND CONTRACTOR INSTALLED. CONTRACTOR TO INSTALL AND WIRE FIBEROPTIC ILLUMINATOR BOXES TO THE DESIGNATED ELECTRICAL CIRCUIT AND CONNECT DMX WIRES TO EACH BOX AS PER MANUFACTURER'S INSTRUCTIONS AND TO REMOTE DMX PLAYBACK DEVICE. OWNER SHALL INSTALL FIBER ALONG WALL SURFACE AND MAKE FIBER CONNECTIONS TO ILLUMINATOR PORT.

OWNER TO FURNISH TO CONTRACTOR A COMPLETE AND OPERATIONAL SYSTEM COMPLETE WITH ILLUMINATOR BOXES. CONTRACTOR TO SUPPLY DMX CABLE AND MISCELLANEOUS MOUNTING EQUIPMENT. 6. OWNER PROVIDED ROSCO DIFFUSING AND LIGHT REDUCTION GELS TO BE FIELD CUT BY OWNER PERSONNEL TO REDUCE LIGHT OUTPUT ON MURAL WALL ONLY. CONTRACTOR TO PROVIDE LIGHT FIXTURES AND MANUFACTURER ACCESSORIES ONLY

7330 NORTH 16TH STREET, SUITE A110
PHOENIX, AZ 85020
TEL 602 336 5200 FAX 602 336 5201
www.hei-eng.com
1050000355

Seal:

Revisions:

109.17.10 ADDENDUM 1 209.23.10 ADDENDUM 2 310.21.10 Bulletin #1 801.17.11 Bulletin #6

Drawing Set: OUT TO BID/LL/PERMIT

Drawing Type: **ELECTRICAL SYMBOLS** AND LEGENDS

Drawn By: 09.03.10

Sheet Number: