

ORC003

09.09.2022



Prepared by: Suzanne Marinello, P.E.

Jacob Gradwohl

Yuki Klein

Hyslop Field Research Laboratory

3455 NE Granger Ave

Corvallis, OR 97330

Table of Contents

Abbreviations	1
Disclaimer	2
Preface	3
Related Contacts	4
Building Efficiency Measure (EEM) Summary	4
Building Description	5
Best Practice	7
Energy Cost Analysis	8
Major Energy Consuming Equipment	9
Mechanical Systems	9
Lighting Systems	10
Controls	10
Detailed Energy Efficiency Measures	11
EEM 1: Lighting Upgrade	11
EEM 2: Occupancy Sensors	13
EEM 3: Envelope Upgrade	15
EEM 4: Programmable Thermostats	18
EEM 5: Motor Upgrade	19
Appendix	20
Light Fixture Photos	20
Mechanical Photos	24

Abbreviations

AFUE	Annual Fuel Utilization Efficiency	HWP	Heating Water Pump
AHU	Air Handling Unit	IAC	Industrial Assessment Center
BTU	British Thermal Unit	kBtu	1,000 Btus
CFM	Cubic Feet (per) Minute	kW	Kilowatt
CMU	Concrete Masonry Unit	kWh	Kilowatt-hours
CV	Constant Volume	lbs	Pounds
DAT	Discharge Air Temperature	LPD	Lighting Power Density
DDC	Direct Digital Control(s)	MBH	kBtu/hr (1,000 BTU/hr)
DegF	Degrees Fahrenheit	MAT	Mixed Air Temperature
DOE	Department of Energy	OAT	Outside Air Temperature
DHW	Domestic Hot Water	RAT	Return Air Temperature
dP	Discharge Pressure	RF	Return Fan
dT	Delta T (Temperature difference)	SAT	Supply Air Temperature
DX	Direct Expansion	sf	Square Feet
EEM	Energy Efficiency Measure	SF	Supply Fan
EFLH	Estimated Full Load Hours	SOO	Sequence of Operations
ETO	Energy Trust of Oregon	SP	Static Pressure
EUI	Energy Use Index	TMY3	Typical Meteorological Year
HC	Heating Coil	TU	Terminal Unit
HP	Horsepower	VAV	Variable Air Volume
Hr	Hour	VFD	Variable Frequency Drive
HVAC	Heating Ventilating & Air Conditioning	W	Watts
HW	Heating Water	Yr	Year

Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

The intent of this energy analysis is to estimate energy savings associated with the recommended energy efficiency upgrades. This report is not intended to serve as a detailed engineering design document. Any description of proposed improvements that may be diagrammatic in nature are for the purpose of documenting the basis of cost and savings estimates for potential energy efficiency measures only. Detailed design efforts may be required by the participant to implement measures recommended as part of this energy analysis. While the recommendations in this study have been reviewed for technical accuracy and are believed to be reasonably accurate, all findings listed are estimates only. Actual savings and incentives may vary based on final installed measures and costs, actual operating hours, energy rates and usage.

Preface

The Commercial Building Energy Audit (CBEA) program is funded by the DOE and structured within the framework of its predecessor and parent program, the Industrial Assessment Center (IAC). The purpose of the CBEA is to provide customers with free energy assessments of commercial buildings, thereby increasing energy efficiency while simultaneously expanding the workforce of building efficiency professionals through the application of student participation from partnered colleges and universities. The scope of such audits is limited in nature, for the express purpose of identifying no-cost and low-cost energy savings opportunities, and a general view of potential capital improvements. This is accomplished by means of utility usage and billing evaluation, along with observation and analysis of energy using systems. The findings and recommendations within this report represent the conditions observed at the time of this site survey. Conditions and equipment usage are subject to change, and therefore the conclusions expressed within this report may not be evident in the future. The CBEA audit team has endeavored to meet what it believes is the applicable standard of care ordinarily exercised by others in conducting this energy audit. No other warranty, express or implied, is made regarding the information contained in this report.

Related Contacts

Participant (Customer) Contact	
Contact Name	Lowell Faucett
Title	Oregon State University Architect
Phone	541-737-5903
Email	lowell.fausett@oregonstate.edu
Participant (Customer) Contact	
Contact Name	Joshua Price
Title	Hyslop Research Facility Director
Phone	971-285-0306
Email	joshua.price@oregonstate.edu
CBEA Contact	
Contact Name	Suzanne Marinello P.E.
Title	Lead Energy Analyst Lead Instructor
Phone	541-207-8205
Email	marinellos@lanecc.edu
CBEA Contact	
Contact Name	Jacob Ray Gradwohl
Title	Lead Student Intern
Email	gradwoja@oregonstate.edu
CBEA Contact	
Contact Name	Yuki Klein
Title	Student Intern
Email	kleiny@oregonstate.edu

Building Efficiency Measure (EEM) Summary

These energy efficiency measures (EEMs) are suggested for the facility. Cost savings are based on average utility rates for electricity and natural gas. Actual rates and cost savings will differ. Non-energy cost benefits are related to cost-savings due to avoided maintenance. Simple payback is estimated using current utility rates and estimated project costs, which may vary over time.

Table 1. EEM Cost Estimates

Measure Number	Measure Description	Annual Energy and Cost Savings			Measure Cost and Simple Payback		
		Electricity Savings		Gas Fuel Savings Therms	Total Cost Savings	Measure Cost	Simple Payback Year
		kWh	kW				
EEM 1	Lighting Upgrade*	30258	10	-	\$ 3,123	\$ 37,260	12
EEM 2	Occupancy Sensors	6750	-	-	\$ 683	\$ 3,000	4
EEM 3	Building Insulation*	34860	-	-	\$ 3,529	\$ 72,976	20.7
EEM 4	Programmable Thermostats	7500	-	-	\$ 759	\$ 2,250	3
EEM 5	Premium Efficient Motors*	604	-	-	\$ 61	\$ 300	5
Totals (Recommended Measures)		79972		0	\$ 8,155	\$ 115,786	14

Building Description

The Field Research Laboratory is a 16,500 sf building in Corvallis, Oregon. The laboratory was originally constructed in 1973. There has been one major addition on the northside of the facility, but the date of the addition is unknown.

The primary objective of the Field Research Laboratory is to conduct field research, extension, and teaching related to the development, production, and management of agronomic crops. The laboratory operates all year round. There is no schedule for the lights, staff come and go on their own accord. All lighting is controlled by manual wall switching.

The building is shaped like a backwards “c,” with the entrance of the building (bottom of the c configuration) is where the labs, office, rest rooms, and storage closet rooms are located. The hall that connects to upper and lower part of the building is where the coolers, cabinet dryers, and the larger labs are located. The upper part of the “c” configuration is where the fumigation, laboratory, and seed storage rooms are located.

The labs near the front entrance have been upgraded to double pane, vinyl framed windows. The exterior walls of the front entrance have also been upgraded to (approx) R-11 wall insulation. The remaining windows of the facility are the original single pane, metal frame windows. Except for the front entrance, the exterior walls are uninsulated, consisting of wood framing and wood siding. There is no ceiling or roof insulation visible. All the windows are manually operated to provide ventilation.

The section where the cooler and dryer are located is covered by expanded metal and concrete flooring. The cooler is refrigerated with a split system Carrier unit, with evaporators mounted along the wall, and the outdoor condensing unit mounted on the ground adjacent to the space. The ceiling of the walk-in consists of lay-in ceiling tiles with fluorescent light fixtures. Condensation is visible on the surface of the light fixtures, indicating a need for a vapor barrier in the space.

The north end of the facility (the addition) consists of an open storage room. This space is heated by a ceiling mounted gas fired unit heater. There is a hood located in the room with make-up air from wall mounted exterior wall louvers.

The laboratories are used to conduct agricultural research. Crops are collected from the surrounding fields and processed on site. The main staff consists of students conducting research and their occupancy schedules vary depending on the season. At the time of the site visit, there were observed to be less than 10 occupants present. The facility is heated with electric wall heaters which are manually controlled by wall mounted thermostats. There is no mechanical ventilation in any of the labs and offices.

There is no air conditioning of the labs or offices, except for a couple single wall mounted air conditioning units located in one of the labs and the maintenance garage.

Best Practice

This audit is per ASHRAE Level 1 requirements. The building's energy cost and efficiency were assessed by analyzing 2021 utility data.

Utility analysis was used to produce reports on the monthly consumption of both electricity and natural gas.

The mechanical and lighting schedules were used to generate outlines of energy usage in terms of demand and energy consumption.

A site visit conducted on July 26, 2022 provided a walk-through survey of the facility including its construction, operation, and maintenance, and major energy consuming equipment. Feedback from the customer related to facility performance and comfort was used to inform the survey and the resulting recommendations within this report.

The data was then used to identify no-cost and low-cost measures for improving energy efficiency. Because calculations at this level are minimal, savings and costs are approximate.

Energy Cost Analysis

Table 2. 2021 Energy Use

2021 Electrical Data						
Month	kWh	kWh Charge	Charge / kWh	kW	kW Charge	Fees
Jan	9,400	978	\$0.104	36	\$ 228	\$ 110
Feb	12,840	1,266	\$0.099	40	\$ 226	\$ 110
Mar	10,200	1,068	\$0.105	46	\$ 228	\$ 110
Apr	12,720	1,190	\$0.094	40	\$ 226	\$ 110
May	11,360	1,130	\$0.099	36	\$ 228	\$ 110
Jun	12,560	1,188	\$0.095	36	\$ 226	\$ 110
Jul	9,280	923	\$0.099	36	\$ 228	\$ 110
Aug	7,960	861	\$0.108	40	\$ 226	\$ 110
Sep	7,640	837	\$0.110	40	\$ 228	\$ 110
Oct	9,960	1,024	\$0.103	36	\$ 226	\$ 110
Nov	10,120	1,053	\$0.104	40	\$ 228	\$ 110
Dec	10,680	1,108	\$0.104	36	\$ 226	\$ 110
TOTALS	124,720	\$12,626.00	\$0.10	462.00	\$2,724.00	\$1,320.00

2021 Natural Gas Data					
Month	Therms	Cost	Cost / Therm	Other Charges	Total
Jan	223.1	\$178.97	\$0.802	\$58.00	\$236.97
Feb	254.7	\$204.32	\$0.802	\$16.87	\$221.19
Mar	66.2	\$53.10	\$0.802	\$44.45	\$97.55
Apr	18.9	\$15.16	\$0.802	\$32.31	\$47.47
May	9.6	\$7.70	\$0.802	\$28.04	\$35.74
Jun	798.4	\$640.47	\$0.802	\$18.81	\$659.28
Jul	757.0	\$607.26	\$0.802	\$16.05	\$623.31
Aug	146.9	\$117.84	\$0.802	\$16.05	\$133.89
Sep	113.1	\$90.73	\$0.802	\$16.11	\$106.84
Oct	255.5	\$204.96	\$0.802	\$16.79	\$221.75
Nov	921.5	\$796.26	\$0.864	\$61.93	\$858.19
Dec	381.3	\$362.92	\$0.952	\$55.52	\$418.44
TOTALS	3,946.2	\$3,279.69	\$0.83	\$380.93	\$3,660.62

Major Energy Consuming Equipment

Mechanical Systems

There were no mechanical schedules available for the building but the following information was obtained through observation.

The facility has no cooling system except a couple post-construction wall mounted air conditioners for some workspaces. Heating in the offices and labs is provided by wall mounted electric heaters. Heating in the north process labs is provided by gas fired unit heaters mounted directly in the space.

There is a walk-in cooler provided with a split system air conditioning unit. The evaporator is in the room and the condenser is located outside the lab building.

In the main entrance corridor there is a gas fired Reznor unit which provides process drying of crops and seeds.

Domestic water heating is provided by two tank type electric water heaters. Water heating is limited to lab and restroom sinks

The following tables detail the information available through nameplates. Please see Appendix II for accompanying figures.

Table 3. Split System Schedule

Tag	Area Served	Manufacturer	Model
C-1	Refrigerator	(Unreadable)	OHB10L44-E

Table 4. Water Heater Schedule

Tag	Manufacturer	Model	Manufacture Date	Capacity (Gal)
WH-1	General Electric	PE40M09AAH	July 2011	40
WH-2	Rheem	PRoE50 T2 AH95	November 2015	50

Table 5. Motor Schedule

Tag	Manufacturer	Model
M-1	A.O. Smith	SOP2201
M-2	Century	SC-213-FC3-35
M-3	Baldor	35B101P499H1

Lighting Systems

The lighting in the space consists of 15 fixture types as detailed from the Architect. Please see Appendix I for accompanying figures. A majority of the labs are lit by types A and C, though processing and specialized areas use the remaining types.

Table 6. Existing Lighting

Existing Lighting				
Fixture Type	Description	Watt/Fixture	Quantity	Total Watt per Fixture
A	Surface Wrap with acrylic lens, 4 ft with 2 lamps fluorescent	60	79	4740
B	Industrial - Open lamps with reflector 4 ft long 4 lamps fluorescent	160		0
C	Surface Wrap with acrylic lens, 8 ft with 2 lamps fluorescent	120	10	1200
D	Industrial strip - Open lamps with reflector 8 ft long with 4 lamps	120		0
E	Keyless Incandescent	60	8	480
F	High mount round HAT incandescent or CFL	300	5	1500
G	Jelly jar incandescent	100		0
H	Pendant stem - HAT incandescent	300	6	1800
I	Classified (explosion proff) jelly jar incandescent	200	4	800
J	Industrial strip with specular reflector 4 ft with 2 lamps	60	56	3360
K	Ice cube trap 4 ft 2 lamp T12 fluorescent	120	4	480
L	Troffer 2 x 4 4 lamp fluorescent	120	2	240
M	Exterior Barn Light	200	4	800
N	Exterior Small wall pack over man door	75	1	75
O	Exterior Wallpack medium front entrance	175	2	350
			SUM	15825

Controls

Lighting and heating operate during occupied periods and are manually controlled.

Detailed Energy Efficiency Measures

EEM 1: Lighting Upgrade

EXISTING CONDITIONS

The general lighting of the space consists of 15 different fixtures. These fixtures are old and mostly fluorescent, with an estimated range of 60 to 300 watts per fixture depending on the type.

PROPOSED MEASURE DESCRIPTION

Replace existing lamps with LED lamps for each fixture. These are estimated to be 20 to 80 watts depending on the type.

Table 7. Lighting Fixture Upgrade

Existing Lighting					Proposed Lighting				
Fixture Type	Description	Watt/Fixture	Quantity	Total Watt	Fixture Type	Description	Watt/Fixture	Quantity	Total Watt
A	Surface Wrap with acrylic lens, 4 ft with 2 lamps fluorescent	60	79	4740	L1	EMS-L48-4000LM-IMAFL-WD-40K-80CRI	24	79	1896
B	Industrial - Open lamps with reflector 4 ft long 4 lamps fluorescent	160	10	1600	L2	EMS-L24-9000LM-PST-MD-40K-80CRI	59	10	590
C	Surface Wrap with acrylic lens, 8 ft with 2 lamps fluorescent	120	10	1200	L3	EMS-L96-9000LM-IMAFL-WD-40K-80CRI	53	10	530
D	Industrial strip - Open lamps with reflector 8 ft long with 4 lamps	120	0	0	L4	EMS-L96-9000LM-IMAFL-WD-40K-80CRI	53	0	0
E	Keyless Incandescent	60	8	480	L5	LED MEDIUM BASE LAMP	20	8	160
F	High mount round HAT incandescent or CFL	300	1	300	L6	PXLW-10000LM-WD-40K-80CRI-PM	74	1	74
G	Jelly jar incandescent	100	1	100	L7	PXLW-5000LM-WD-40K-80CRI-PM	35	1	35
H	Pendant stem - HAT incandescent Clasified (explosion proff) jelly jar incandescent	300	6	1800	L8	PXLW-10000LM-WD-40K-80CRI-PM	74	6	444
I	Industrial strip with specular reflector 4 ft with 2 lamps	200	4	800	L9	HRL-8L-GO-AS-50K-CM	94	4	376
J	Ice cube trap 4 ft 2 lamp T12 fluorescent	60	56	3360	L10	EMS-L48-4000LM-IMAFL-WD-40K-80CRI	24	56	1344
K	Troffer 2 x 4 4 lamp fluorescent	120	4	480	L11	EMS-L48-4000LM-IMAFL-WD-40K-80CRI	24	4	96
L	Exterior Barn Light	200	2	240	L12	HVT-2X4-DOP-5500-40K	52	2	104
M	door	75	1	800	L13	PCLL	79	4	316
N	entrance	175	1	75	L14	HLWPC2-P10-40K-TFTM	28	1	28
O				175	L15	HLWPC2-P30-40K-TFTM	71	1	71
				16150					6064
				On Time Hrs					
Total Existing Watt		16150	3000	48450	kWh				
Total Proposed Watt		6064	3000	18192	kWh				

SAVINGS METHODOLOGY

Savings are estimated using a spreadsheet calculation.

ESTIMATED COST

The estimated installation costs are as described in Table 7. Assuming 3000 hours of run time for all fixtures and \$0.1 per kWh the following savings were estimated.

EEM #1 Estimated Savings		
Annual Energy Usage & Savings Estimate	Baseline Electric Usage (kWh)	48450
	Proposed Electric Usage (kWh)	18192
	Electric Savings (kWh)	30258
	Electric Cost Savings (\$)	\$ 3,063
	Demand Savings (kW)	10
	Electric Demand Savings (\$)	\$ 59
	Baseline Natural Gas Usage (Therms)	-
	Proposed Natural Gas Usage (Therms)	-
	Natural Gas Savings (Therms)	-
	Natural Gas Savings (\$)	-
	Annual Energy Cost Savings	\$ 3,123
Measure Cost & Simple Payback	Project Cost	\$ 37,260
	Simple Payback (Cost/Savings)	11.9

EEM 2: Occupancy Sensors

EXISTING CONDITIONS

There are currently no occupancy sensors on site.

PROPOSED MEASURE DESCRIPTION

Add occupancy sensors for each room/area.

SAVINGS METHODOLOGY

Savings are estimated using a spreadsheet calculation. Existing ON time is estimated at 3000 hrs. Occupancy sensors are estimated to reduce ON time to 2500 hours per year, a reduction of 500 hrs. (A reduction of approx. 16% in ON time).

Existing Conditions
Rooms do not have Occupancy Sensors

Fixture Type	Description	Watt/Fixture	Quantity	Total Watt Fixture Type
A	Surface Wrap with acrylic lens, 4 ft with 2 lamps fluorescent	60	79	4740
B	Industrial - Open lamps with reflector 4 ft long 4 lamps fluorescent	160		0
C	Surface Wrap with acrylic lens, 8 ft with 2 lamps fluorescent	120	10	1200
D	Industrial strip - Open lamps with reflector 8 ft long with 4 lamps	120		0
E	Keyless Incandescent	60	8	480
F	High mount round HAT incandescent or CFL	300	1	300
G	Jelly jar incandescent Pendant stem - HAT	100	1	100
H	incandescent	300	6	1800
I	Clasified (explosion proff) jelly jar incandescent	200	4	800
J	Industrial strip with specular reflector 4 ft with 2 lamps	60	56	3360
K	Ice cube trap 4 ft 2 lamp T12 fluorescent	120	4	480
L	Troffer 2 x 4 4 lamp fluorescent	120	2	240

kWh = watts/1000 x ON time hr

13500 Watt Existing
40500 kWh Existing
33750 kWh Proposed

Assume On Time at 3000 hrs per year
Assume reduce to 2500 hrs per year ON time

ESTIMATED COST

Assuming \$0.1 per kWh, 20 sensors, and \$150 per sensor, the following costs were estimated.

EEM #2 Estimated Savings		
Annual Energy Usage & Savings Estimate	Baseline Electric Usage (kWh)	40500
	Proposed Electric Usage (kWh)	33750
	Electric Savings (kWh)	6750
	Electric Cost Savings (\$)	\$ 683
	Baseline Natural Gas Usage (Therms)	
	Proposed Natural Gas Usage (Therms)	-
	Natural Gas Savings (Therms)	-
	Natural Gas Savings (\$)	\$ -
	Annual Energy Cost Savings	\$ 683
Measure Cost & Simple Payback	Project Cost	\$ 3,000
	Simple Payback (Cost/Savings)	4.4

EEM 3: Envelope Upgrade

EXISTING CONDITIONS

The current envelope includes an uninsulated sheet metal roof, concrete and sheet metal walls. The exterior walls of the front offices have been upgraded with R-11 insulation and double pane windows with vinyl frames. The remaining walls and roof are uninsulated. In addition, the remaining lab windows are single pane, metal framed operable windows.

PROPOSED MEASURE DESCRIPTION

Extend insulation throughout spaces to create a full thermal envelope. Replace single pane windows with updated and thermally efficient windows. Insulate the roof to further thermal envelope.

SAVINGS METHODOLOGY

Savings based on spreadsheet calculations and eQUEST modeling.




Figure 1. eQUEST model




Figure 2. Estimated energy usage for current building




Figure 3. Estimated energy usage for retrofit building

ESTIMATED COST

The envelope retrofit was estimated with prices sourced from the Architect for an approximate total of \$73,000. Combined with the eQUEST energy data, the following costs were estimated.

EEM #3 Estimated Savings			
Annual Energy Usage & Savings Estimate	Baseline Electric Usage (kWh)		135180
	Proposed Electric Usage (kWh)		100320
	Electric Savings (kWh)		34860
	Electric Cost Savings (\$)	\$	3,529
	Baseline Natural Gas Usage (Therms)	-	
	Proposed Natural Gas Usage (Therms)	-	
	Natural Gas Savings (Therms)	-	
	Natural Gas Savings (\$)	-	
	Annual Energy Cost Savings	\$	3,529
	Measure Cost & Simple Payback	Project Cost	\$
Simple Payback (Cost/Savings)			20.7

EEM 4 Programmable Thermostats

EXISTING CONDITIONS

There are 15 electric wall heaters manually controlled.

PROPOSED MEASURE DESCRIPTION

Install programmable thermostats to create setpoints and manual override for temperature control.

SAVINGS METHODOLOGY

Savings based on spreadsheet calculations.

$\text{Elec Heater Use (kWh)} = \text{kW} \times \text{hrs ON}$

Currently the electric unit heaters do not have programmable thermostats and are manually controlled. Providing programmable thermostats will reduce the amount of time the spaces are heated when the spaces are unoccupied. ON time is estimated to be reduced by 100 hours per year per unit heater.

15 Electric Unit Heaters

5 kW per heater

Overheating hours = 100 hr /unit heater

$5 \text{ kW} \times 15 \times 100 \text{ hrs} = 7500 \text{ kWh}$ overheating energy use per year.

ESTIMATED COST

At \$150 per thermostat the following costs were estimated.

EEM #4 Estimated Savings		
	Electric Savings (kWh)	7500
	Electric Cost Savings (\$)	\$ 759
	Baseline Natural Gas Usage (Therms)	0
	Proposed Natural Gas Usage (Therms)	0
	Natural Gas Savings (Therms)	0
	Natural Gas Savings (\$)	\$ -
	Annual Energy Cost Savings	\$ 759
Measure Cost & Simple Payback	Project Cost	\$ 2,250
	Simple Payback (Cost/Savings)	3.0

EEM 5: Motor Upgrade

EXISTING CONDITIONS

There are currently 3 85% efficiency 3 hp motors.

PROPOSED MEASURE DESCRIPTION

Replace with 91.7% efficiency motors.

SAVINGS METHODOLOGY

Savings based on spreadsheet calculations.

EEM #5		Calculations	
Premium Efficiency Motors			
		Power (kW) = HP x .746 kW/HP x Load/efficiency	
Elec Cost =	\$ 0.101	Hrs =	1200 hrs run time per year
		Load =	75%
Existing Conditions		efficiency =	84% existing
3 Qty 3 HP Motors 84% eff		efficiency =	91.70% Premium
Energy Use Existing =	7194 kWh	Energy Use = Power (kW) x hrs	
		Material Cost =	\$ 100 per motor
Proposed Conditions			
3 Qty 3 HP Motors 91.7% eff		6590 kWh	

ESTIMATED COST

For 1200 operation hours per year and \$250 per motor the following savings were estimated.

EEM #5 Estimated Savings		
Annual Energy Usage & Savings Estimate	Baseline Electric Usage (kWh)	7194
	Proposed Electric Usage (kWh)	6590
	Electric Savings (kWh)	604
	Electric Cost Savings (\$)	\$ 61
	Baseline Natural Gas Usage (Therms)	-
	Proposed Natural Gas Usage (Therms)	-
	Natural Gas Savings (Therms)	-
	Natural Gas Savings (\$)	-
	Annual Energy Cost Savings	\$ 61
Measure Cost & Simple Payback	Project Cost	\$ 300
	Simple Payback (Cost/Savings)	4.9

Appendix

I. Light Fixture Photos



Figure A: Existing Fixture A



Figure B: Existing Fixture C



Figure C: Existing Fixture E



Figure D: Existing Fixture F



Figure E: Existing Fixture H



Fixture F: Existing Fixture I




Figure G: Existing Fixture J



Figure H: Existing Fixture K




Figure I: Existing Fixture L



Figure J: Existing Fixture M



Figure K: Existing Fixture N



Figure L: Existing Fixture O

II. Mechanical Photos



Figure M: Typical Wall Mounted Electric Heater



Figure N: Motor



Figure O: Motor Tag 1




Figure P: Motor Tag 2



Figure S: Indoor Evaporator of Walk-In Cooler



Figure T: Reznor Gas Fired Dryer



Figure U: Gas Fired Unit Heater



Figure V: Typical Domestic Water Heater